


VIEW-A (DISPLAY INTERFACE-ENLARGED)



- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS..
- 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK
- 3. ALL DIMENSIONS ARE IN INCHES [MILLIMETERS].

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

Schneider Electric

| TITLE: | RACK PDU, SWITCHED |
|--------|--------------------------------------|
| | ZERO U, 12.5kW, 208V |
| | INPUT: CS8365L - 10 FEET CORD |
| OUT | PUT: (21)IEC 320 C13, (3)IEC 320 C19 |
| | VIEW DETAILS |

| | ZERO U, 12.5kW, 208V | DWG NO: | 7998B | REV. |
|----------------|--|--------------------|-----------------|------------|
| | INPUT: CS8365L - 10 FEET CORD OUTPUT: (21)IEC 320 C13, (3)IEC 320 C19 | DRAWN BY: JAYAPRA | AKASH 24-AUG-16 | THIRD |
| VIEW – DETAILS | | ENGINEER: KATIE | RICK 07-DEC-16 | ANGLE |
| | PROJECT: SUBMITTAL DRAWINGS SHEET 2 OF 2 | APPROVED BY: KATIE | RICK 07-DEC-16 | PROJECTION |