

Date : 12/15/2016

American Power Conversion
Holdings Inc., Taiwan Branch
3F No. 205, Sec. 3, Beixin Rd.
231 Xindian Dist., New Taipei City
Taiwan - R.O.C.
Attn: Jason Lai

Re. : CU US + Canada Certificate

Type of Equipment : Uninterruptible Power Supply
Model Designation : See Certificate
Certificate No. : CU 72092843 0009
File No. : 30983111 009
Engineer/Contact : Andreas Klinker
Standard(s) : UL 1778:2005 R10.11
C22.2 No. 107.3-05

Dear Madame or Sir,

The above referenced technical equipment has been tested and was found to be in compliance with the listed test requirement(s). Enclosed, please find the TUV Rheinland approval document No. CU 72092843 0009.
It authorizes you to label the listed product(s) with the TUV Rheinland Mark identified in the approval document.
For compliance, the Test Mark must be on the approved unit.

Your product is subject to regular factory follow-up inspections as well as annual certificate and factory registration fees.

In using the TUV Rheinland Mark you are obligated to comply with the TUV Rheinland of North America Service Agreement.

If we can be of any further assistance to you, please do not hesitate to contact us.

Sincerely yours,
Certification Body



Dipl.-Ing. F. Stoelzel
QA Certification Officer

Enclosure

Certificate



Certificate no.

CU 72092843 09

License Holder:

American Power Conversion
Holdings Inc., Taiwan Branch
3F No. 205, Sec. 3, Beixin Rd.
231 Xindian Dist., New Taipei City
Taiwan

Manufacturing Plant:

International Precision
Assemblies, Inc.
Lot 6 Blk 8, Phase II Peza
4106 Rosario Cavite
Philippines

Test report no.: USA-AK 30983111 009

Client Reference:

Tested to: UL 1778:2005 R10.11
C22.2 No. 107.3-05

Certified Product: Uninterruptible Power Supply

License Fee - Units

Addition:

1

Model Designation: 6) BX1350MYYYYYYYY, 7) BX1500MYYYYYYYY
(Y = 0-9, a-z, A-Z, +, *, #, _, -, blank)

Rated Voltage: 6)-7) AC 120V, 60Hz
Rated Current: 6) 1350VA; 7) 1500VA
Rated Power: 6) 810W; 7) 900W
Output Ratings: see Appendix

1

Appendix: 1; 1-24

Licensed Test mark:



Date of Issue
(day/mo/yr)
15/12/2016